

Warren's Industrial Local Limits

Pollutant	Local Limits	
Barium*	0.5	mg/L
Chromium	1.5	mg/L
Hex Chromium*	0.12	mg/L
Molybdenum*	0.06	mg/L
Selenium*	0.075	mg/L
Antimony	1.19	mg/L
Arsenic	0.2	mg/L
Cadmium	0.136	mg/L
Copper	1.32	mg/L
Cyanide (free)	0.335	mg/L
Lead	0.574	mg/L
Mercury	0.001	mg/L
Nickel	1.8	mg/L
Silver	0.196	mg/L
Zinc*	0.3	mg/L
TDS	7500	mg/L
pH	6 to 10	S.U.
Oil & Grease	100	mg/L

Surchargable Thresholds**		
BOD	200	mg/L
COD	600	mg/L
TSS	250	mg/L
Ammonia	35	mg/L
Total Phosphorus	15	mg/L

Thresholds may be exceeded, with permission and will require additional charges.

* Certain industrial users may have mass-based limits that result in concentrations different than what is shown here.

Effective Date: Pending final approval of Warren Sewer Use Ordinance Chapter 924 by the Council of the City of Warren.

Notice: Local limits and the associated mass-loading allocations are subject to periodic changes as needed to maintain compliance with the WPCF discharge permit.